



RIVERDALE CITY FIRE DEPARTMENT

PEER REVIEW FOR PROTECTION SYSTEMS

In accordance with Section 104.7.2 of the International Fire Code, Riverdale City Fire Department will require a "technical opinion and report" (peer review) of all plans for the installation and/or modification of an automatic fire protection system, installation, and/or modification of fire alarm and detection systems and related equipment, fire pumps and related fuel tanks, jockey pumps, controllers and related equipment, installation, modification, or removal from service of a standpipe system.

Exceptions to required peer reviews:

- 1) Installation of fire hydrants and underground fire protection supply lines.
- 2) Pre-engineered kitchen hood suppression systems.
- 3) Installation or relocation of less than 20 sprinkler heads.
- 4) Installation or relocation of less than 5 alarm/notification appliances.

The following companies and/or individuals have been approved by Riverdale City Fire Department as design professionals who can conduct third party plan review. These companies/individuals cannot review plans or drawings that have been developed by their own firm or representatives.

West Coast Code Consultants

Scott W. Adams, PE

207 East Gordon Avenue – Suite 4

Layton UT 84041

801-547-8133

permideskfire@wc-3.com

Protection Consultants Inc.

Bob Goodloe

1199 S. Main St. #101

Centerville, UT 84014

801-295-6070/801-677-6070 fax

bob@pciut.com

Craig Blue, PE Inc

Craig Blue, PE

1971 W. 3300 S. #A

West Valley City, UT 84119

801-886-3473

craig@cbluepe.com

Please submit plans to the company of your choice. When their review and written comments are completed, resubmit these plans to the Riverdale City Fire Department at the address located below, or plans may be forwarded by the peer review company to Riverdale City Fire Department.

Riverdale City Fire Department

Paul Flaig / Fire Marshal

4600 S Weber River

Riverdale, UT 84405

801-394-5541 Ext. 1288

pflaig@riverdalecity.com