



RIVERDALE CITY FIRE DEPARTMENT

PEER REVIEW FOR PROTECTION SYSTEMS

In accordance with Section 104.7.2 of the International Fire Code, Riverdale City Fire Department will require a “technical opinion and report” (peer review) of all plans for the installation and/or modification of an automatic fire protection system, installation, and/or modification of fire alarm and detection systems and related equipment, fire pumps and related fuel tanks, jockey pumps, controllers and related equipment, installation, modification, or removal from service of a standpipe system.

Exceptions to required peer reviews:

- 1) Installation of fire hydrants and underground fire protection supply lines.
- 2) Pre-engineered kitchen hood suppression systems.
- 3) Installation or relocation of less than 20 sprinkler heads.
- 4) Installation or relocation of less than 5 alarm/notification appliances.

The following companies and/or individuals have been approved by Riverdale City Fire Department as design professionals who can conduct third party plan review. These companies/individuals cannot review plans or drawings that have been developed by their own firm or representatives. **(Companies with AFS after their name are approved to review water based automatic fire suppression systems only.)**

Craig Blue, PE Inc.

Craig Blue, P.E.

1971 W. 3300 S. #A
West Valley City, UT 84119
801-886-3473
craig@cbluepe.com

Superior Fire Protection Services (AFS Only)

Rafael Castillo

5406 W. 11000 N. #510
Highland, UT 84003
801-228-7656
rcastillo415@yahoo.com

Protection Consultants Inc.

Bob Goodloe

1199 S. Main St. #101
Centerville, UT 84014
801-295-6070/801-677-6070 fax
bob@pciut.com

Van Boerum & Frank Associates

DeAnn W. Dunlavy

330 S. 300 E
Salt Lake City, UT 84111
801-530-3148/801-530-3150 fax
craig@cbluepe.com

Spectrum Engineers

Jeff Dubois, FPE

324 S. State St. #400
Salt Lake City, UT 84111
801-401-8496/801-652-1467 cell
jdd@spectrum-engineers.com

Impact Fire Protection Services (AFS Only)

Lynn Robinson

1823 Sorrento Dr.
Woods Cross, UT 84087
385-210-5351
impactfps@comcast.net

West Coast Code Consultants

Scott W. Adams

8821 S. Redwood Rd. #A
West Jordan, UT 84088
385-237-3722/435-901-2891 cell
scotta@wc-3.com

Please submit plans to the company of your choice. When their review and written comments are completed, resubmit these plans to the Riverdale City Fire Department at the address located below, or plans may be forwarded by the peer review company to Riverdale City Fire Department.

Riverdale City Fire Department

Randy Koger (Fire Marshal)

4600 S Weber River
Riverdale, UT 84405
801-436-1241
rkoger@riverdalecity.com